## GOVT. OF ASSAM OFFICE OF THE DIRECTOR, FIRE AND EMERGENCY SERVICES, ASSAM, GUWAHATI.



No. F&ES/FPW/12(12

Dated Guwahati the 14 2 22

The Principal, For Kendriya Vidyalaya,

Gerua, Tamulpur, Dist:- Tamulpur, Assam.

NO OBJECTION CERTIFICATE IN RESPECT OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN THE KENDRIYA VIDYALAYA LOCATED AT GERUA, TAMULPUR, DIST:- TAMULPUR, ASSAM.

07.04.2022 Dated With reference to your completion report under No. Nil and on the basis of the Inspection Report submitted by Station Officer, Jitu Boro, I hereby certify that the building as per description below at Dag No.40 Patta No. - Mouza -, (Place- Gerua, Tamulpur) has been inspected in respect of implementation of inbuilt Fire Fighting/ Fire Prevention/ Escape means measures and is declared fit in respect of fire safety. The Fire & Emergency Services, Assam has No Objection in its occupation /utilization for the purpose of EDUCATIONAL subject to conditions mentioned over leaf.

DETAILS OF APPROVED OCCUPATION:-

GROUND FLOOR: -

FIRST FLOOR: -

1. Floor area: - 28938 m

1. Floor area: - 28938 m<sup>2</sup>

2. Purpose of utilization: -For Educational Purpose. 2. Purpose of utilization: -For Educational Purpose.

SECOND FLOOR: -

1. Floor area: - 28938 m<sup>2</sup>

2. Purpose of utilization: -For Educational Purpose.

## Details of Fire Fighting measures found in working condition:

- Hose Reel Hose system
- 2. Down Comer system
- 3. Manually Operated Electric Fire Alarm system
- 4. Fire Extinguishers- 57 Nos.
- 5. Terrace Water Tank6. Terrace Pump

Deputy Dimettor now for and on between the process of Firement Entergency Services, Assam, Guwahati.

Dated Guwahati the

NO. F&ES/FPW/

Copy to:-

- 1. The Deputy Commissioner, Tamulpur, Assam for information.
- 2. The Superintendent of Police, Tamulpur, Assam for information.
- 3. The Chairman, No. 3 Tamulpur (Kalbari) VCDC, Tamulpur, Assam for information.

4. The Station Officer, Rangia F&ES Station, for information and necessary action.

Deputy Director. for and on behalf of Director of Fire and Emergency Services, Assam, Guwahati.

Contd...P/2

## **CONDITIONS:-**

- 1. The N.O.C. is valid up to: 31.03.2023
- 2. There should not be any change of Trade for which this License has been issued.
- 3. There should not be any structural change in the building either horizontally or vertically. There should not also be any change in the existing arrangements.
- 4. The Fire Fighting equipments should be in serviceable condition at all time.
- 5. Water reservoir should always be kept full up to brim.
- 6. The entrance and exit and the water reservoir should always be free from any obstruction/
- 7. The N.O.C. is liable to be cancelled if the premises (for which the N.O.C. is granted) when inspected are not found conforming to the description and condition under which this

for and or Director of Fire a